



Cambridgeport

SUBMITTAL


Part Number
2006688

SUBMITTED TO _____
COMPANY _____
JOB NAME _____
EQUIPMENT _____
SIGNATURE _____
DATE _____



FEATURES:

1. ONE PIECE WELDED CONSTRUCTION
2. CURB ADAPTER MADE OF HEAVY GAUGE GALVANIZED STEEL.
3. ALL WELDS ARE COATED WITH A GALVANIZED COMPOUND.
4. GASKETING IS PROVIDED FOR UNIT TO CURB ADAPTER SEALING.
5. CURB ADAPTER IS FULLY INSULATED.
6. SUPPLY TRANSITION INCLUDED.



MATERIAL: 18 GA (0.0516) 198.8 LBS

FEATURES

- ONE PIECE WELDED CONSTRUCTION
- FACTORY INSTALLED SUPPLY TRANSITIONS
- FULLY INSULATED
- DESIGNED FOR EVEN WEIGHT DISTRIBUTION
- FABRICATED OF HEAVY GAUGE G90 GALVANIZED STEEL
- ALL WELDS SPRAYED WITH GALVANIZING COMPOUND
- GASKET PROVIDED FOR UNIT TO ADAPTER SEALING

SUBMITTAL

Approved By: _____

Date: _____

Cambridgeport

NORTH
8 Farman Drive
Salem Industrial Park
Salem MA 01952
1-800-648-2872
1-877-648-2872

SOUTH
2525 Lamar Ave.
Lamar Industrial Park
Memphis TN 38118

HVAC Accessories & Engineered Systems

UNLESS OTHERWISE SPECIFIED:	CUST. JOB NO.	DATE:	3/12/12	DESCRIPTION:
TOLERANCES:	OLD UNIT	NEW UNIT		
DECIMALS = + .003	Len. LGA150S	Car. 48HJ008		ASS'Y, ADAPTER
FRACTURES = + .016				
ANGLES = + 1°				
MATERIAL CONDITIONS:	NO.			
REMOVE ALL BURRS & SHARP EDGES				
ALL DIMENSIONS ARE O.D.	2006688 Sub	DETAIL OF	SHEET 1 OF 1	PART NO. 2006688 Sub

CAMBRIDGEPORT STRONGLY RECOMMENDS CONFIRMING THE DIMENSIONS ON THIS SUBMITTAL

CURB ADAPTERS ARE BASED ON UNIT MANUFACTURERS STANDARD CURB DIMENSIONS.
CAMBRIDGEPORT CANNOT BE RESPONSIBLE FOR ANY DEVIATIONS FROM FACTORY DIMENSIONS OR INCORRECT MODEL NUMBERS.