

SUBMITTAL

Part Number
2010096

SUBMITTED TO _____
COMPANY _____
JOB NAME _____
EQUIPMENT _____
SIGNATURE _____
DATE _____

REVISIONS	
ZONE	REV.

© 2007 COX ENGINEERING DBA CAMBRIDGEPORT AIR SYSTEMS. THE INFORMATION CONTAINED IN THIS DOCUMENT IS PROPRIETARY TO COX ENGINEERING COMPANY DBA CAMBRIDGEPORT AIR SYSTEMS. THIS DOCUMENT OR THE INFORMATION CONTAINED IN WHOLE OR IN PART MAY NOT BE ISSUED TO ANOTHER PARTY WITHOUT WRITTEN CONSENT AND AUTHORIZATION FROM CAMBRIDGEPORT.

SUBMITTAL

MATERIAL: 18GA,(0.0516) 209.9 LBS.

FEATURES:

- ONE PIECE WELDED CONSTRUCTION
- CURB ADAPTER MADE OF HEAVY GAUGE GALVANIZED STEEL.
- ALL WELDS ARE COATED WITH A GALVANIZED COMPOUND.
- GASKETING IS PROVIDED FOR UNIT TO CURB ADAPTER SEALING.
- CURB ADAPTER IS FULLY INSULATED.
- SUPPLY TRANSITION AND RETURN PLENUM INCLUDED.

Approved By: _____
Date: _____

Cambridgeport			
HVAC Accessories & Engineered Systems			
UNLESS OTHERWISE SPECIFIED:	CUST. NO.	DRAWN	JSL
TOLERANCES:	CUST. NO.	DATE:	3/18/2019
DECIMALS = ± .003	CARRIER 48DR012 (10A)		
FRACTIONS = ± 1/16	NEW CARRIER 48HC14 (74A)		
ANGLES = ± 1°	SUBMITTAL 2010096		
MATERIAL CONDITIONS:	NO.		
REMOVE ALL BURRS & SHARP EDGES	DETAIL OF		
ALL DIMENSIONS ARE O.D.	2010096	SHEET 1	CF 1
		PART NO.	2010096
		REV.	

FEATURES

- ONE PIECE WELDED CONSTRUCTION
- FACTORY INSTALLED SUPPLY TRANSITIONS
- FULLY INSULATED
- DESIGNED FOR EVEN WEIGHT DISTRIBUTION
- FABRICATED OF HEAVY GAUGE G90 GALVANIZED STEEL
- ALL WELDS SPRAYED WITH GALVANIZING COMPOUND
- GASKET PROVIDED FOR UNIT TO ADAPTER SEALING

CAMBRIDGEPORT STRONGLY RECOMMENDS CONFIRMING THE DIMENSIONS ON THIS SUBMITTAL

CURB ADAPTERS ARE BASED ON UNIT MANUFACTURERS STANDARD CURB DIMENSIONS.
CAMBRIDGEPORT CANNOT BE RESPONSIBLE FOR ANY DEVIATIONS FROM FACTORY DIMENSIONS OR INCORRECT MODEL NUMBERS.