

SUBMITTAL

Part Number
2016056

SUBMITTED TO _____
COMPANY _____
JOB NAME _____
EQUIPMENT _____
SIGNATURE _____
DATE _____

REVISIONS	
ZONE	REV. DESCRIPTION DATE APPROVED
© 2017 COX ENGINEERING DBA CAMBRIDGEPORT AIR SYSTEMS. THE INFORMATION CONTAINED IN THIS DOCUMENT IS PROPRIETARY TO COX ENGINEERING COMPANY DBA CAMBRIDGEPORT AIR SYSTEMS. THIS DOCUMENT OR THE INFORMATION CONTAINED IN WHOLE OR IN PART MAY NOT BE ISSUED TO ANOTHER PARTY WITHOUT WRITTEN CONSENT AND AUTHORIZATION FROM CAMBRIDGEPORT. MATERIAL: 18 GA GALV. (68.1 LBS.) SUBMITTAL Approved By: _____ Date: _____ FEATURES: - ONE PIECE WELDED CONSTRUCTION - CURB ADAPTER MADE OF HEAVY GAUGE GALVANIZED STEEL. - ALL WELDS ARE COATED WITH A GALVANIZED COMPOUND. - GASKETING IS PROVIDED FOR UNIT TO CURB ADAPTER SEALING. - CURB ADAPTER IS FULLY INSULATED. - SUPPLY TRANSITION AND RETURN PLENUM INCLUDED.	

Cambridgeport

NORTH
8 Farnham Drive
Salem, MA 01962

1-800-648-2872
1-877-648-2872

SOUTH
2529 Lamar Ave.
Lamar, MO 64503
Memphis TN 38119

HVAC Accessories & Engineered Systems

UNLESS OTHERWISE SPECIFIED:	CUST. JOB NO.	DRAWN	PRG	DESCRIPTION
TOLERANCES:	DECIMALS = ± .003	FRACCTIONS = ± 1/16	ANGLES = ± 1°	YORK PCG4A30
MATERIAL CONDITIONS:	REMOVE ALL BURRS & SHARP EDGES	ALL DIMENSIONS ARE O.D.	DETAIL OF	2016056
			SHEET	1 OF 1
			PART NO.	2016056
			REV.	

FEATURES

- ONE PIECE WELDED CONSTRUCTION
- FACTORY INSTALLED SUPPLY TRANSITIONS
- FULLY INSULATED
- DESIGNED FOR EVEN WEIGHT DISTRIBUTION
- FABRICATED OF HEAVY GAUGE G90 GALVANIZED STEEL
- ALL WELDS SPRAYED WITH GALVANIZING COMPOUND
- GASKET PROVIDED FOR UNIT TO ADAPTER SEALING

CAMBRIDGEPORT STRONGLY RECOMMENDS CONFIRMING THE DIMENSIONS ON THIS SUBMITTAL

CURB ADAPTERS ARE BASED ON UNIT MANUFACTURERS STANDARD CURB DIMENSIONS.
CAMBRIDGEPORT CANNOT BE RESPONSIBLE FOR ANY DEVIATIONS FROM FACTORY DIMENSIONS OR INCORRECT MODEL NUMBERS.